



**OFFICE OF THE CORPORATION OF THE CITY, NAGPUR
(FIRE & EMERGENCY SERVICE)**

Chhatrapati Shivaji Maharaj Prashashkiya Bhawan, Mahanagar Palika, Civil lines, Nagpur - 440 001

Ph. No.: 0712-2567777

Fax No.: 0712-2561584



No. MFS/NMC/FES/ **027** /2022

Date:- **01/02/2023**

To,

✓ Smt. Jayshri Suresh Nayar,
Kh. No. 84/1, Nagalwadi,
Tah. Hingna, Nagpur.

Sub: - "Final No Objection Certificate" for your Existing Construction of Educational Building on Kh. No. 84/1, Nagalwadi, Tah. Hingna, Nagpur.

- Ref:- 1) Recommendation Letter No. GA/1782/FB on dated 17/02/2012
2) Your Application Dated 03/01/2023 Compliance Certificate for Educational Building
3) Certificate Submitted by License Agency M/s. Speed Engineering & Safety Services (License No. MFS-LA/RF-163, RD-156)
4) Part Compliance Certificate No. (Ground Floor) GA/176/FB Dt. 28/04/2016

This has reference to the above. This office has No Objection for (Final) Fire Approval for following Existing Educational Building

Total Plot area of the said Building is **3097.316 Sq. Mtrs** and Total Built up area is **2943.168 Sq Mtr.**

The Compliance Certificate for Existing Educational Building **Ground Floor to 2nd Floor** is issued on the basis of the Inspection Report of Station Officer (HQ), Fire & Emergency Service dated 04/01/2023

Since the Fire Fighting arrangements provided is installed by License Agency i.e. **M/s. Speed Engineering & Safety Services (License No. MFS-LA/RF-163, RD-156)** issued by Directorate of Maharashtra Fire Service and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Final No-Objection Certificate" for your following building having built up area admeasuring to **2943.168 Sq Mtr.** The detail of the Building Construction is as under,

SR. No.	No. Of Floor	Built Up Area	Occupancy/Use	Height of Building
1.	Ground Floor	1006.466 sqm	Parking & Educational Use	12.600 mtr (As per Sanctioned Plan)
2.	First Floor	968.351 sqm	Educational Use	
3.	Second Floor	968.351 sqm	Educational Use	
Total Built up area		2943.168 sqm		


Statutory Provisions under Maharashtra Fire Prevention and Life Safety Measures Act, 2006.

1. Under Section 3 of "Maharashtra Fire Prevention and Life Safety Measures

Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.

2. It is presumed that you have completed the work adhering to the provisions under **Section-3** of the said Act.
3. **Under sub-section (3)** of Section 3, it is responsibility of the Owner or the Occupier as the case maybe, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in **sub-section (1)**.
4. Under **sub section (4) of Section 3**, no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.
5. The Fire Fighting System provided by you in the premises as per Provisional No-Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.
6. The condition mentioned in the **"Provisional No-Objection Certificate"** will **remain unchanged**. The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No-Objection Certificate from this office is essential.**
7. As per Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Section 25-Annexure-Part III, Smt. Jayshri Suresh Nayar The Owner/Occupier has paid Fire Protection Fund Fees amounting to Rs. 72,000/- (Ninety Six Thousand Three Hundred Fifty Six Only) vide receipt No. 056416 dated 25/01/2012 with paid on Nagpur Municipal Corporation Fire and Emergency Service .

NAGPUR MUNICIPAL CORPORATION
FIRE SERVICE DEPARTMENT



1/2/23
Rajendra D. Uchake
I/C Chief Fire Officer /Nominated Officer
Fire and Emergency Service
Nagpur Mpl. Corporation

Copy submitted to:

1. The Director, MFS, Mumbai for information, please
2. The Building Eng. (NMRDA) Nagpur.



VISHWAKARMA & ASSOCIATES

IN FIRE & SAFETY SINCE 1979

- Fire Engineer (NFSC)
- Member Of Fire Expert Committee (MSBTE)
- Authorised Safety Auditor (DISH)
- Breathing Apparatus
- Qualified Fire Auditor – MFPR – 2009
- Expert Panelist (NSC)
- Safety Diploma (CLI)
- Experties in NFPA/NBC/Factories Act
- Advisory On Concession

FORM B

(See Section 3(3) and rule 4(2))

Six monthly certificates are to be given in every January and July by the owner or occupier for Compliance with Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I / We have carried out an inspection of the Fire Prevention and Life Safety Measures Installed in the following building or premises namely.

**NAME OF BUILDING: M/S "ESSENCE INTERNATIONAL SCHOOL
ADD. KH. NO. 84/1, PH NO. 6, MOUZA NAGALWADI
TAH. HINGNA, NAGPUR.**

I / We further certify that these installations in the above-mentioned building are maintained in Good repair and efficient conditions during the period of **1st Jan -2026 to 30th June- 2026**. As required Under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act. 2006 (Mah III of 2007) the details of the inspection of installations carried out by me/us are mentioned in the Report appended herewith.

Place: MOUZA NAGALWADI
TAH. HINGNA, NAGPUR.
Date – 03.09.2026

KAILASH
KANDUJI
VISHWAKARMA

Digitally signed by KAILASH
KANDUJI VISHWAKARMA
Date: 2026.09.03 20:04:51
+05'30'

Authorized Signatory
Address of the Licensed Agency
M/s. Vishwakarma & Associates
Survey No. 32, Flat No. 103, Plot No. 48,
Tulip Apartment, Tingre Nagar, Pune-411032
Ex-Faculty – National Fire Service College, Nagpur
Advance Diploma In fire engineering – NFSC
Grade-I fire engineer (India)



VISHWAKARMA & ASSOCIATES

IN FIRE & SAFETY SINCE 1979

To,

The fire Officer

Annexure for Form B:

NAME OF BULDING: M/S “ESSENCE INTERNATIONAL SCHOOL						
ADD. KH. NO. 84/1, PH NO. 6, MOUZA NAGALWADI TAH. HINGNA, NAGPUR.						
Classification of building		educational building		Height of Building		9 MTR
Terrace pump 1 No.		900 LPM				
Pump Electrical panel		1 NOS		Fire Alarm Panel 1 NO. 4 ZONE		
Wet Riser/ Down		100 mm		wings		
Fire Service Inlet		2 No.		Yard Hydrant		2 No
Recommendation Certificate No.						
SR. NO	List of Equipment	Ground Floor	First Floor	Second Floor	Total Nos.	Status
1	HYDRANT VALVE	5	3	3	11	Active
2	HOSE REEL HOSE (30 MTR)	5	3	3	11	Active
3	HOSE BOX	5	3	3	11	Active
4	63 MM FIRE HOSE (30 MTR)	5	3	3	11	Active
5	SHORT BRANCH	5	3	3	11	Active
6	BUTTERFLY VALVE	2	-	-	2	Active
7	CO2 FIRE EXTINGUISHER	2	-	-	2	Active
8	ABC STORE PR.FIRE EXTINGUISHER	19	18	16	53	Active
9	FIRE EXIT	1	1	1	3	Active
10	MANUAL CALL POINT	3	3	3	9	Active
11	ELETRICAL HOOTER	3	3	3	9	Active
12	Fire Alarm Panel 4 ZONE	1	-	-	1	Active
13	TWO CORE CABLE WITH ACCESSORIES	125mtr	125mtr	150mtr	400mtr	Active

Note: Compile with reference to NBC 2005

Place: MOUZA NAGALWADI
TAH. HINGNA, NAGPUR.
Date - 03.09.2026

KAILASH KANDUJI
VISHWAKARMA

Digitally signed by KAILASH
KANDUJI VISHWAKARMA
Date: 2026.09.03 20:05:18
+05'30'

Authorized Signatory
Address of the Licensed Agency
M/s. Vishwakarma & Associates
Survey No. 32, Flat No. 103, Plot No. 48,
Tulip Apartment, Tingre Nagar, Pune-411032
Ex-Faculty – National Fire Service College, Nagpur
Advance Diploma In fire engineering – NFSC
Grade-I fire engineer (India)